

INTERPRETATIVE BULLETIN G-1-78
VENTING REQUIREMENTS FOR SYSTEMS UTILIZING
ANTI-SIPHON TRAP VENT DEVICES - 3280.611(d)

Where anti-siphon trap vent devices are used in a secondary venting system, each plumbing fixture to be protected by an anti-siphon trap vent device must be "individually protected" by the device. Accordingly, wet venting of any secondary vent system using anti-siphon trap vent devices is prohibited. A maximum of two fixtures, each of which is individually protected by an anti-siphon trap vent device, may be drained by a common 1-1/2 inch drain line. Three or more fixtures, each of which is individually protected by an anti-siphon trap vent device, shall be drained by a pipe with a minimum diameter of 2 inches.