

INTERPRETATIVE BULLETIN I-1-77
LOCATION AND TYPE OF
OUTDOOR RECEPTACLE OUTLET
3280.801(b), 3280.806(d)(8), AND 3280.81(a)

The outdoor receptacle outlet required by section 3280.806(d)(8) shall not be installed on the underside of the mobile home.

The outdoor receptacle outlet shall be of a type that is:

- (a) gasket-covered; and
- (b) acceptable for use in wet locations as follows:
 - (I) in a weatherproof enclosure, the integrity of which is not affected when the receptacle is in use (attachment plug cap inserted);or
 - (ii) weatherproof when a self-closing receptacle cover is closed and where the receptacle is not likely to be used with other than portable tools or other portable equipment not usually left connected to the mobile home.

This Interpretative Bulletin is issued pursuant to 24 CFR 3280.1(c) and 3282.113. The Secretary deems that it would not be in the public interest to issue this interpretation for public comment in the Federal Register or otherwise treat this Interpretative Bulletin as rulemaking.