

INTERPRETATIVE BULLETIN I-2-76
EXTERIOR LIGHTING OUTLET
REQUIREMENTS - 3280.813(a)

A wall switch controlled exterior lighting outlet is required at each exterior entrance door to the mobile home in accordance with paragraph 210-26 of the National Electrical Code (NFPA No. 70-1975).
[PARAGRAPH 210-70 NFPA - No. 70-1993, effective October 25, 1994]