

TITLE: [ADDRESS AND SIGNAGE](#)

VERSION: V2.1

DATE PUBLISHED: 4/2/21

---

DEFINITION: Unique number and name identifiers assigned to the property.

PURPOSE: Assist in identifying and locating the property.

NAME VARIANTS: Building identification number; Property or development name sign; House number; Unit number

COMMON MATERIALS: Plastic; Metal; Wood via laminate; Paint; Engraving; Any combination of the previous

COMMON COMPONENTS: Arabic numerals; Alphabetical letters; Frame; Mounting; Protective enclosures; Lighting component

LOCATION:  Unit      None  
 Inside      None  
 Outside      Near building entrances (either above or alongside the entrance or on a nearby post) and road entrances where the property's private road meets a public road.

MORE INFORMATION: None

---

DEFICIENCY 1: Address, signage, or building identification codes are broken, illegible, or not visible.

LOCATION:  Outside

---

**DEFICIENCY I — OUTSIDE:** [ADDRESS, SIGNAGE, OR BUILDING IDENTIFICATION CODES ARE BROKEN, ILLEGIBLE, OR NOT VISIBLE.](#)

**DEFICIENCY CRITERIA:** Address or building identification codes are broken, illegible, or not visible.

**HEALTH AND SAFETY DETERMINATION:** Standard      The Standard Health and Safety category includes deficiencies that, if evident in the home or on the property, present a moderate risk of an adverse medical event requiring a healthcare visit; cause temporary harm; or if left untreated, cause or worsen a chronic condition that may have long-lasting adverse health effects; or that the physical security or safety of a resident or their property could be compromised.

**CORRECTION TIMEFRAME:** 30 days

**HCV PASS / FAIL:** Fail

**HCV CORRECTION TIMEFRAME:** 30 days

**RATIONALE:**

CODE	CATEGORY	TYPE	DESCRIPTION	EXPLANATION
R2	Safety	Indirect	Resident could be injured because of this condition.	If address, signage, or building identification codes are broken, illegible, or not visible, and there is an emergency, then first responders may be delayed if they are unable to efficiently locate the property.
M2	Routine Maintenance	Direct	It is reasonable to expect that this deficiency would be identified through routine daily observations and facilities management would prioritize work orders to fix this deficiency.	If address, signage, or building identification codes are broken, illegible, or not visible, then it is likely that routine or daily maintenance activities are not being addressed.

**INSPECTION PROCESS:**

- OBSERVATION:**
- Look at the property and locate any signage or address.
  - Look at individual buildings on the property and locate any signage or building identification codes identifying the building.
- REQUEST FOR HELP:** - None
- ACTION:** - Approach the entrance to the building from the main street, road, or parking area.
- More Information:** - None

**TOOLS OR EQUIPMENT:**

- REQUIRED:** - None
- USEFUL:** - None

**SUMMARY OF CHANGES**

**TITLE:** ADDRESS AND SIGNAGE  
**VERSION:** V2.1  
**DATE PUBLISHED:** 4/2/21

FIELD	CHANGE	VERSION	DATE
----	Copy edits	V2.1	2021-04-02
Deficiency 1		V2.0	2020-10-28
Health and Safety Determination	Added standardized description		
HCV Pass / Fail	Field added; response input as "Fail"		
Overall Formatting	Complete rework of document format and layout	V1.3	2020-07-31
Definition	Revised definition	V1.3	2020-07-31
Purpose	Field added	V1.3	2020-07-31
Name Variants	Revised name variants	V1.3	2020-07-31
Common Components	Revised common components	V1.3	2020-07-31
More Information	Field added	V1.3	2020-07-31
Deficiency 1	Separated by inspectable location – Outside	V1.3	2020-07-31
Title	Revised title; added inspectable location		
Deficiency Criteria	Revised deficiency criteria		
Health and Safety Determination	Added standardized description		
Correction Timeframe	Field added; response input as "Within 30 days"		
HCV – Correction Timeframe	Field added; response input as "Within 30 days"		
Rationale	Revised rationale explanations; added standardized codes and descriptions		
Inspection Process	Revised observation, request for help, action, and more information		
Tools or Equipment	Field added to deficiency		
Deficiency 2	Removed	V1.3	2020-07-31
Rationales	Updated following in-house review and public comment	V1-2	2019-12-26

---

Health and Safety Determinations

Updated following in-house review and public comment

VI-2

2019-12-26

---