

TITLE: GARAGE DOOR
VERSION: V2.2
DATE PUBLISHED: 06/23/22

DEFINITION: A large door on a garage that opens either manually or by an electric motor. Garage doors are frequently large enough to accommodate automobiles and other vehicles. Small garage doors may be constructed as a single panel that tilts up and back across the garage ceiling.

PURPOSE: Provide barrier to outside elements and provide contained storage of vehicle or personal property.

COMMON COMPONENTS: Primary door; Track; Door balance; Springs; Motor; Safety stop; Hinges; Weather seal; Opening controls; Lighting

LOCATION:

<input checked="" type="checkbox"/>	Unit	Attached or detached garage
<input checked="" type="checkbox"/>	Inside	Attached or detached garage
<input checked="" type="checkbox"/>	Outside	Attached or detached garage

MORE INFORMATION: Garage walls will be evaluated under the Wall Covering and Finish – Interior and Wall Covering and Finish – Exterior standards, respectively.

DEFICIENCY 1: Garage door has a hole.
LOCATION: Unit Inside Outside

DEFICIENCY 2: Garage door does not open, close, or remain open or closed.
LOCATION: Unit Inside Outside

DEFICIENCY I — UNIT: GARAGE DOOR HAS A HOLE.

DEFICIENCY CRITERIA: Garage door has a hole of any size that penetrates through to the interior.

HEALTH AND SAFETY DETERMINATION: Moderate The Moderate Health and Safety category includes deficiencies that, if evident in the home or on the property, present a moderate risk of an adverse medical event requiring a healthcare visit; cause temporary harm; or if left untreated, cause or worsen a chronic condition that may have long-lasting adverse health effects; or that the physical security or safety of a resident or their property could be compromised.

CORRECTION TIMEFRAME: 30 days

HCV PASS / FAIL: Fail

HCV CORRECTION TIMEFRAME: 30 days

INSPECTION PROCESS:

OBSERVATION: - Visually inspect the garage door to identify any holes.

REQUEST FOR HELP: - None

ACTION: - None

MORE INFORMATION: - For the purposes of this deficiency, holes may include missing (i.e., evidence of prior installation, but now not present or is incomplete) or broken panels or windows.

DEFICIENCY I — INSIDE: GARAGE DOOR HAS A HOLE.

DEFICIENCY CRITERIA: Garage door has a hole of any size that penetrates through to the interior.

HEALTH AND SAFETY DETERMINATION: Moderate The Moderate Health and Safety category includes deficiencies that, if evident in the home or on the property, present a moderate risk of an adverse medical event requiring a healthcare visit; cause temporary harm; or if left untreated, cause or worsen a chronic condition that may have long-lasting adverse health effects; or that the physical security or safety of a resident or their property could be compromised.

CORRECTION TIMEFRAME: 30 days

HCV PASS / FAIL: Fail

HCV CORRECTION TIMEFRAME: 30 days

INSPECTION PROCESS:

OBSERVATION: - Visually inspect the garage door to identify any holes.

REQUEST FOR HELP: - None

ACTION: - None

MORE INFORMATION: - For the purposes of this deficiency, holes may include missing (i.e., evidence of prior installation, but now not present or is incomplete) or broken panels or windows.

DEFICIENCY I — OUTSIDE: GARAGE DOOR HAS A HOLE.

DEFICIENCY CRITERIA: Garage door has a hole of any size that penetrates through to the interior.

HEALTH AND SAFETY DETERMINATION: Moderate The Moderate Health and Safety category includes deficiencies that, if evident in the home or on the property, present a moderate risk of an adverse medical event requiring a healthcare visit; cause temporary harm; or if left untreated, cause or worsen a chronic condition that may have long-lasting adverse health effects; or that the physical security or safety of a resident or their property could be compromised.

CORRECTION TIMEFRAME: 30 days

HCV PASS / FAIL: Fail

HCV CORRECTION TIMEFRAME: 30 days

INSPECTION PROCESS:

OBSERVATION: - Visually inspect the garage door to identify any holes.

REQUEST FOR HELP: - None

ACTION: - None

MORE INFORMATION: - For the purposes of this deficiency, holes may include missing (i.e., evidence of prior installation, but now not present or is incomplete) or broken panels or windows.

DEFICIENCY 2 — UNIT: GARAGE DOOR DOES NOT OPEN, CLOSE, OR REMAIN OPEN OR CLOSED.

DEFICIENCY CRITERIA: Door will not open and remain open.
OR
Door will not close and remain closed.

HEALTH AND SAFETY DETERMINATION: Moderate The Moderate Health and Safety category includes deficiencies that, if evident in the home or on the property, present a moderate risk of an adverse medical event requiring a healthcare visit; cause temporary harm; or if left untreated, cause or worsen a chronic condition that may have long-lasting adverse health effects; or that the physical security or safety of a resident or their property could be compromised.

CORRECTION TIMEFRAME: 30 days

HCV PASS / FAIL: Fail

HCV CORRECTION TIMEFRAME: 30 days

INSPECTION PROCESS:

OBSERVATION: - Look to see if the garage door can be opened manually or electronically.

REQUEST FOR HELP: - None

ACTION: Manual Door:

- Open the door manually.
- Verify the door remains open.
- Manually close the door.
- Verify the door remains closed.

Electronic Door:

- Use remote, keypad, or switch to open the door electronically.
- Verify the door remains open.
- Use remote, keypad, or switch to close the door.
- Verify nothing is in the path of the sensors.
- Verify the door remains closed.

MORE INFORMATION: - None

DEFICIENCY 2 — INSIDE: GARAGE DOOR DOES NOT OPEN, CLOSE, OR REMAIN OPEN OR CLOSED.

DEFICIENCY CRITERIA: Door will not open and remain open.
OR
Door will not close and remain closed.

HEALTH AND SAFETY DETERMINATION: Moderate The Moderate Health and Safety category includes deficiencies that, if evident in the home or on the property, present a moderate risk of an adverse medical event requiring a healthcare visit; cause temporary harm; or if left untreated, cause or worsen a chronic condition that may have long-lasting adverse health effects; or that the physical security or safety of a resident or their property could be compromised.

CORRECTION TIMEFRAME: 30 days

HCV PASS / FAIL: Fail

HCV CORRECTION TIMEFRAME: 30 days

INSPECTION PROCESS:

OBSERVATION: - Look to see if the garage door can be opened manually or electronically.

REQUEST FOR HELP: - None

ACTION: Manual Door:

- Open the door manually.
- Verify the door remains open.
- Manually close the door.
- Verify the door remains closed.

Electronic Door:

- Use remote, keypad, or switch to open the door electronically.
- Verify the door remains open.
- Use remote, keypad, or switch to close the door.
- Verify nothing is in the path of the sensors.
- Verify the door remains closed.

MORE INFORMATION: - None

DEFICIENCY 2 — OUTSIDE: GARAGE DOOR DOES NOT OPEN, CLOSE, OR REMAIN OPEN OR CLOSED.

DEFICIENCY CRITERIA: Door will not open and remain open.
OR
Door will not close and remain closed.

HEALTH AND SAFETY DETERMINATION: Moderate The Moderate Health and Safety category includes deficiencies that, if evident in the home or on the property, present a moderate risk of an adverse medical event requiring a healthcare visit; cause temporary harm; or if left untreated, cause or worsen a chronic condition that may have long-lasting adverse health effects; or that the physical security or safety of a resident or their property could be compromised.

CORRECTION TIMEFRAME: 30 days

HCV PASS / FAIL: Fail

HCV CORRECTION TIMEFRAME: 30 days

INSPECTION PROCESS:

OBSERVATION: - Look to see if the garage door can be opened manually or electronically.

REQUEST FOR HELP: - None

ACTION: Manual Door:
- Open the door manually.
- Verify the door remains open.
- Manually close the door.
- Verify the door remains closed.

Electronic Door:
- Use remote, keypad, or switch to open the door electronically.
- Verify the door remains open.
- Use remote, keypad, or switch to close the door.
- Verify nothing is in the path of the sensors.
- Verify the door remains closed.

MORE INFORMATION: - None

SUMMARY OF CHANGES

TITLE: GARAGE DOOR
VERSION: V2.2
DATE PUBLISHED: 06/23/22

FIELD	CHANGE	VERSION	DATE
----	Abbreviated published version	V2.2	2022-06-23
Name Variants	Removed from published version		
Common Materials	Removed from published version		
Rationale	Removed from published version		
Tools or Equipment	Removed from published version		
Deficiency 1		V2.2	2022-06-23
Health and Safety Determination	Unit: Relabeled from "Standard" to "Moderate" Inside: Relabeled from "Standard" to "Moderate" Outside: Relabeled from "Standard" to "Moderate"		
Deficiency 2		V2.2	2022-06-23
Health and Safety Determination	Unit: Relabeled from "Standard" to "Moderate" Inside: Relabeled from "Standard" to "Moderate" Outside: Relabeled from "Standard" to "Moderate"		
----	Copyedits	V2.1	2021-04-02
Deficiency 1		V2.0	2020-10-28
Title	Copyedits		
Health and Safety Determination	Added standardized description		
HCV Pass / Fail	Field added; response input as "Fail"		
Deficiency 2		V2.0	2020-10-28
Health and Safety Determination	Added standardized description		
HCV Pass / Fail	Field added; response input as "Fail"		
Rationale	Explanation copyedits		

Overall Formatting	Complete rework of document format and layout	VI.3	2020-07-31
Title	Revised title	VI.3	2020-07-31
Definition	Revised definition	VI.3	2020-07-31
Purpose	Field added	VI.3	2020-07-31
Name Variants	Revised name variants	VI.3	2020-07-31
Common Materials	Revised common materials	VI.3	2020-07-31
Common Components	Revised common components	VI.3	2020-07-31
Location	Revised inspectable locations	VI.3	2020-07-31
More Information	Field added	VI.3	2020-07-31
Deficiency 1	Separated by inspectable locations — Unit, Inside, and Outside	VI.3	2020-07-31
Title	Revised title; added inspectable locations		
Deficiency Criteria	Revised deficiency criteria		
Health and Safety Determination	Added standardized description		
Correction Timeframe	Field added; response input as "Within 30 days"		
HCV — Correction Timeframe	Field added; response input as "Within 30 days"		
Rationale	Revised rationale categories, types, and explanations; added standardized codes and descriptions		
Inspection Process	Revised observation, request for help, action, and more information		
Tools or Equipment	Field added to deficiency; response revised		
Deficiency 2	Separated by inspectable locations — Unit, Inside, and Outside	VI.3	2020-07-31
Title	Revised title; added inspectable locations		
Deficiency Criteria	Revised deficiency criteria		
Health and Safety Determination	Added standardized description		
Correction Timeframe	Field added; response input as "Within 30 days"		
HCV — Correction Timeframe	Field added; response input as "Within 30 days"		
Rationale	Revised rationale categories, types, and explanations; added standardized codes and descriptions		
Inspection Process	Revised observation, request for help, action, and more information		

Tools or Equipment	Field added to deficiency		
Rationales	Updated following in-house review and public comment	VI-2	2019-12-23
Health and Safety Determinations	Updated following in-house review and public comment	VI-2	2019-12-23