Building Exterior	Bldg 149	Walls - Missing Pieces/Holes/Spalling	L2		0.1		
Unit 5626B	Bldg 149	Bathroom - Water Closet - Damaged/Clogged/Missing	L2		0.64		
Unit 5626B	Bldg 149	Hot Water Heater - Gas Fired Unit - Missing/Misaligned (L3		0.86		
Building Exterior	Bldg 150	Foundations - Cracks/Gaps		L2		0.43	
Unit 5604	Bldg 150	Hot Water Heater - Gas Fired Unit - Missing/Misaligned C	Chimney (LT)	L3		0.88	
Building Exterior	Bldg 150	Foundations - Cracks/Gaps	L1		0.2		
Building Exterior	Bldg 150	Roofs - Missing/Damaged Components from Downspout	L1		0.09		
Building Exterior	Bldg 150	Walls - Missing Pieces/Holes/Spalling	L2		0.19		
Building Exterior	Bldg 152	Roofs - Missing/Damaged Components from Downspout	L3		0.36		
Building Exterior	Bldg 152	Roofs - Missing/Damaged Shingles	L2		0.4		
Unit 86E	Bldg 152	Kitchen - Range Hoods/Exhaust Fans- Excessive Grease	L3		0.32		
Unit 86E	Bldg 152	Outlets/Switches - Missing/Broken Cover Plates	L3		0.17		
Jnit 86E	Bldg 152	Smoke Detector - Missing Inoperable	L3		<0.05		
Building Exterior	Bldg 152	Roofs - Missing/Damaged Components from Downspout	/Gutter	L1		<0.05	
Building Exterior	Bldg 152	Walls - Missing Pieces/Holes/Spalling		L2		0.1	
Jnit 5626B	Bldg 152	Bathroom - Water Closet - Damaged/Clogged/Missing		L2		0.66	
Jnit 5626B	Bldg 152	Hot Water Heater - Gas Fired Unit - Missing/Misaligned C	Chimney (LT)	L3		0.88	
Building Exterior	Bldg 153	Roofs - Missing/Damaged Shingles		L1		0.21	
Building Exterior	Bldg 156	Roofs - Missing/Damaged Components from Downspout	/Gutter	L2		0.1	
Building Exterior	Bldg 156	Roofs - Missing/Damaged Shingles		L1		0.11	
Jnit 86E	Bldg 156	Kitchen - Range Hoods/Exhaust Fans- Excessive Grease	/Inoperable	L3		0.33	
Jnit 86E	Bldg 156	Outlets/Switches - Missing/Broken Cover Plates		L3		0.16	
Jnit 86E	Bldg 156	Smoke Detector - Missing Inoperable		L3		< 0.05	
Building Exterior	Bldg 168	Doors - Damaged Surface (Holes/Paint/Rusting)		L2		< 0.05	
Common Areas	Bldg 168	Electrical - Missing Breakers (LT)		L3		0.24	
Common Areas	Bldg 168	Floors - Needs Paint		L2		< 0.05	
Building Exterior	Bldg 169	Doors - Damaged Frames/Thresholds/Lintels/Trim (NLT)	L1	-	<0.05		
Building Exterior	Bldg 169	Doors - Damaged Surface (Holes/Paint/Rusting)	L1		< 0.05		
Building Exterior	Bldg 169	Roofs - Missing/Damaged Components from Downspout	L1		< 0.05		
Common Areas	Bldg 169	Electrical - Missing Breakers (LT)	L3		0.25		
Common Areas	Bldg 169	Electrical - Missing Covers (LT)	L3		0.25		
Common Areas	Bldg 169	Floors - Needs Paint	L2	-	<0.05		
Building Exterior	Bldg 190	Roofs - Damaged Soffits/Fascia	L1		<0.05		
Building Exterior	Bldg 190	Walls - Missing Pieces/Holes/Spalling	L2		<0.05		