

Building Exterior	Bldg 266	Roofs - Missing/Damaged Components from Downspout/Gutter	L2		<0.05
Building Exterior	Bldg 266	Windows - Damaged/Sills/Frames/Lintels/Trim	L1		<0.05
Building Exterior	Bldg 266	Windows - Peeling/Needs Paint	L1		<0.05
Common Areas	Bldg 266-Garage	Outlets/Switches - Missing/Broken Cover Plates	L1		<0.05
Common Areas	Bldg 266	Electrical - Missing Breakers (LT)	L3		0.12
Common Areas	Bldg 266-Storage	Outlets/Switches - Missing/Broken Cover Plates	L3		0.05
Common Areas	Bldg 266	Walls - Damaged	L2		<0.05
Common Areas	Bldg 266	Walls - Needs Paint	L1		<0.05
Common Areas	Bldg 266	Windows - Damaged/Sills/Frames/Lintels/Trim	L1		<0.05
Building Exterior	Bldg 267	Roofs - Damaged Vents	L1		<0.05
Building Exterior	Bldg 267	Roofs - Missing/Damaged Components from Downspout	L3		<0.05
Building Exterior	Bldg 267	Walls - Cracks/Gaps	L1		<0.05
Common Areas	Bldg 267	Outlets/Switches - Missing/Broken Cover Plates	L1		<0.05
Common Areas	Bldg 267	Ceiling - Holes/Missing Tiles/Panels/Cracks	L1		<0.05
Building Exterior	Bldg 268	Roofs - Damaged Soffits/Fascia	L1		<0.05
Building Exterior	Bldg 268	Roofs - Missing/Damaged Components from Downspout	L3		<0.05
Building Exterior	Bldg 268	Roofs - Missing/Damaged Shingles	L2		<0.05
Common Areas	Bldg 268	Ceiling - Needs Paint	L1		<0.05
Common Areas	Bldg 268	Doors - Damaged Surface (Holes/Paint/Rusting)	L3		0.06
Common Areas	Bldg 268	Walls - Needs Paint	L1		<0.05
Building Exterior	Bldg 273	Roofs - Damaged Vents	L1		<0.05
Building Exterior	Bldg 273	Roofs - Missing/Damaged Components from Downspout/Gutter	L2		<0.05
Building Exterior	Bldg 273	Walls - Cracks/Gaps	L2		<0.05
Building Exterior	Bldg 274	Roofs - Damaged Vents	L1		<0.05
Building Exterior	Bldg 274	Roofs - Missing/Damaged Components from Downspout/Gutter	L2		<0.05
Common Areas	Bldg 274	Outlets/Switches - Missing/Broken Cover Plates	L1		<0.05
Common Areas	Bldg 274	Ceiling - Holes/Missing Tiles/Panels/Cracks	L1		<0.05
Building Exterior	Bldg 275	Roofs - Damaged Soffits/Fascia	L1		<0.05
Building Exterior	Bldg 275	Roofs - Missing/Damaged Components from Downspout/Gutter	L2		<0.05
Building Exterior	Bldg 275	Roofs - Missing/Damaged Shingles	L1		<0.05
Common Areas	Bldg 275	Ceiling - Needs Paint	L2		<0.05
Common Areas	Bldg 275	Doors - Damaged Surface (Holes/Paint/Rusting)	L2		<0.05
Common Areas	Bldg 275	Walls - Needs Paint	L1		<0.05
Building Exterior	Bldg 276	Windows - Broken/Missing/Cracked Panes	L1		<0.05
Common Areas	Bldg 276	Ceiling - Holes/Missing Tiles/Panels/Cracks	L1		<0.05